

RISK ASSESSMENT SHEET – Site Risk Register

Prepared for:			
Site:			
Work Activity:			
Project No.:		Work scope	General site works
Created by		Date	

5 x 5 Risk Matrix						
LIKELIHOOD	5	5	10	15	20	25
	4	4	8	12	16	20
	3	3	6	9	12	15
	2	2	4	6	8	10
	1	1	2	3	4	5
		1	2	3	4	5
CONSEQUENCES						

Risk Rating

High

Medium

Low

Risk Rating (Likelihood x Consequence)

16-25 = High Risk: - Action required to eliminate or reduce risk

9-15 = Medium Risk: - Action required to reduce or control risk

1-8 = Low Risk: - No action required but review where necessary

Activity / Process	Hazard	Risk	Those affected	Initial Risk Rating =			Controls introduced in order to reduce risk	Final Risk Rating=		
				L	C	R		L	C	R
Concreting Operations	Slips, trips and falls Hand arm vibration Noise, Collapse of supporting structure or formwork, Failure of concrete pump hoses.	Dermatitis and concrete burns Health risk Lung cancer Silicosis Asthma Permanent damage to Nerves and blood Supply to fingers, Wrist and hands.	Employees, Sub-Contractors,	4	4	16	1. Manual handling training to be provided to all workers Staff to be informed of the hazards and risks (concrete burns and dermatitis) from contact with concrete. 1. Ensure all PPE is worn. 2. Limit exposure time to vibrating equipment such as concrete pokers. 3. Provide suitable working platforms. 4. Plan/sequence works to ensure operatives do not have stand in concrete. 5. Wash all concrete off skin immediately.	2	2	4

		Severe Injury by falling object.			<p>6. Ensure adequate supervision is provided and that control measures remain valid for the duration of the work.</p> <p>Guidance information</p> <p>1. HSG 46 A Guide for Small Contractors: Site Safety and Concrete Construction.</p>	
--	--	----------------------------------	--	--	--	--

								Other: 1. Anti vibration gloves may be required
---	---	---	---	--	---	---	---	--

ENSURE THAT THE CORRECT PPE FOR THE TASK IS WORN AT ALL TIMES.

This risk assessment should be read in conjunction with all relevant method statements, safe systems of work and associated risk assessments as detailed on the Risk Assessment Briefing Record

All relevant H&S information will be relayed to staff through inductions, toolbox talks and Information displayed around site.

Method Statement Briefing Record

Briefing delivered by:

Position:

Date:

We (the undersigned) have read and understood the attached method statement and will comply with the specified requirements and control measures. If the work activity changes or deviates from that originally envisaged, we will seek further advice and request an amended method statement.

Name (Print)	Signature	Date